

Brute Deluxe

Volume Water Heater

Model BMT2V 500-2000 Indoor/Outdoor

Specification

Date: _____ Bid Date: _____
Project #: _____ Location: _____
Project Name: _____ Engineer: _____
Contractor: _____ Prepared By: _____

Contractor shall supply and install Qty.: _____ Brute Deluxe, BMT2V _____ water heater(s).

The heater shall be a Bradford White Brute Deluxe BMT2V _____, rated at the input and output shown on the schedule. The unit(s) shall be design certified to comply with the current edition of the Harmonized ANSI Z21.10.3 / CSA 4.3 Standard for Gas Water Heaters, and shall be design certified for both indoor and outdoor use. The unit(s) shall be designed and constructed in accordance with the ASME Boiler & Pressure Vessel Code, Section IV requirements for 160 psi (1103 kPa) working pressure, and shall bear the ASME "H" Stamp. The unit(s) shall be constructed to comply with the efficiency requirements of the latest edition of ASHRAE Standard 90.1.

The water tube heat exchanger shall be a straight tube design with ten 7/8" (22mm) inner diameter integral finned cupronickel tubes. The tubes shall be rolled directly into glass-lined cast iron headers, rated for 160 psi (1103 kPa) working pressure. The heat exchanger shall be a low water volume design. All gaskets shall be non-metallic, outside the jacket, and separated from the combustion chamber by at least 3.5" (89mm) to eliminate deterioration from heat. Headers shall have covers permitting visual inspection and cleaning of all internal surfaces. The heat exchanger shall have a ten year warranty.

The piping side header shall have removable flanges, and the water heater design shall permit removal of the complete heat exchanger for service from either the front or top, to facilitate maintenance.

Each unit shall have a pump time delay. The pump time delay shall be adjustable from 0.1 to 10 minutes for continued pump circulation after the call for heat has been satisfied, to remove residual heat from the unit's combustion chamber.

The units shall use a proved hot surface ignition with a 15 second pre-purge cycle to clean out the combustion chamber. Upon a call for heat, if a flame is not detected, the ignition module shall attempt two more times before locking out, and requiring manual reset. If there is a loss of flame signal during a call for heat, the ignition control shall attempt three re-ignition cycles before locking out. (units with some options, such as ASME CSD-1, are built with single-try ignition controls.) The control circuit shall be 24V. Unit shall be 120V, single phase, less than 12 Amps.

Burners shall be multi-port design, and shall be constructed of high temperature stainless steel. The burners shall be designed to mix air and gas, and burn cleanly with NOx emissions not exceeding 10ppm. Burners shall be in easily-removable burner tray assemblies with no more than 4 burners per tray.

The combustion chamber shall be lined with lightweight, ceramic fiberboard insulation to retain heat, and shall be approved for service temperatures of not less than 2000°F (1093°C). The outer jacket shall be a unitized shell finished with acrylic thermo-set paint baked at not less than 325°F (163°C). The frame shall be constructed of galvanized steel for strength and protection. Chamber shall include a sight glass for viewing flame.

Heaters shall have a forced draft design and shall meet a minimum 85% thermal efficiency. The unit shall be designed for vertical venting with standard B-vent as a fan-assisted Category I appliance, and for horizontal venting as a Category III appliance and shall not require an external draft hood. The unit shall accept ducted combustion air, or shall be able to pull combustion air from the room.

The heater shall have two firing stages, and the heater shall have connections for an external staging control, and a selector switch to enable the user to choose between the water heater's staging control or a field-supplied staging control, without bypassing any of the heater's safety controls.

Unit(s) shall have multiple gas trains, such that each gas train shall have a maximum input of 399,000 BTU/hr. Each gas train shall have a gas shutoff valve and main gas valve with built-in redundant valve seats and gas regulator. Flanges or unions shall be used before and after each main gas valve, to permit easy removal of the each gas valve, gas train and burner tray assembly from the front of the unit.

The heater shall be provided with an integral, washable combustion air filter. The air filter shall provide 83% arrestence to protect the burners and blower(s) from debris. The air filter shall be constructed out of open-cell polyurethane foam.

Heater shall include as standard equipment the following controls and trim:

- ASME 160 psi working pressure heat exchanger
- ASME "H" stamp
- Flanged water connections
- Glass-lined cast iron headers
- External header gaskets
- 125 psi (861 kPa) ASME rated pressure relief valve
- Flow switch
- Temperature and pressure gauge
- Multiple operating gas valve/pressure regulators
- Manual "A" gas valve
- Intake air filter
- Multiple, removable burner trays
- Stainless steel burners
- Built-in draft fan(s) for Category I or III venting
- Air pressure switch
- Burner site glass
- 24V control system
- 115/24VAC transformer
- Manual reset high limit
- External controller connections with selector switch
- Hot surface ignition
- On/Off toggle switch
- Pump time delay



200 Lafayette St.
Middleville, MI 49333
Warranty: (800) 531-2111

www.BradfordWhite.com

Litho in U.S.A. © Bradford White 1703 Document 5084-62C-BW