
Brute



Date:	Outdoor Sizes 150-399 Submittal Data
Project #:	BRADFORD WHITE
Engineer:	Project Name:
Prepared By:	Location:
Bid Date:	Contractor:

BNTH

Standard Equipment

- Meets ANSI Z21.13-2013, section 5.26 boilers for outdoor installations
- Electronic PID modulating control with large color touchscreen display
- Password-protected parameters for installer use
- Test feature allows forced min or max firing
- Complete diagnostics for analog and digital inputs
- Displays holds, alerts and errors in clear text form
- Dry alarm contacts for ignition
 failure
- · High condensing efficiency
- Modulation down to 20% of full fire (5:1 turndown)
- · Sealed combustion chamber
- · Pre-mix stainless steel burner
- Low NOx system exceeds the most stringent regulations for air quality - 10 ppm NOx
- Horizontal or vertical direct vent

- · Horizontal vent and air terminals
- Vent and air pipe lengths of up to 100 equivalent feet (each)
- Built-in condensate trap
- · Vent temperature cutoff feature
- · Direct spark ignition system
- · Indirect water heater priority
- Sensor for indirect domestic water tank
- 160 psi maximum working pressure
- Stainless steel heat exchanger with welded construction (no gaskets)
- · ASME "H" stamp
- 75 psi (517 kPa) ASME rated pressure relief valve
- Water flow switch (399-850 only)
- Temperature & pressure gauge
- Drain valve
- Multiple pump control for boiler pump, system pump and indirect domestic water pump, each with delay

 Optional pump (sized to model) available for field installation (285 only)

Hydronic Boiler

Hydronic Boiler

- Integrated PID temperature and ignition controls
- · Large user-interface and display
- · Alarm output
- Accepts external 4-20mA (0-10V with optional convertor) modulation signal
- Outdoor reset with customizable reset curves, domestic hot water override and warm weather shutdown
- Outdoor air temperature sensor
- · On/off toggle switch
- Manual reset high limit
- · Burner site glass
- Zero clearance to combustible surfaces
- Built-in cascade function for up to eight Brutes.
- 10-year limited warranty

Boiler Data

Number of Units:



Fuel

NaturalPropane

Pump Options

Pump included

No pump

Factory Mounted Options

CSD-1

(covers FM & GAP) (500-850)

Low water cutoff (500-850)

High & Low gas pressure switches (500-850)

Additional auto reset high limit

30 psi pressure relief valve

75 psi pressure relief valve (std)125 psi pressure relief valve

150 psi pressure relief valve

Bell for ignition failure











Accessories for Field Mounting

Water flow switch	(150-285	only)
Low water cutoff		

) Boiler pump Concentric vent terminal, 3" Condensate neutralizer kit Variable Speed Pump Control

0 - 10V convertor for modulation Flush-mount terminal, 3" control High & Low gas pressure

switches

Flush-mount terminal, 4" Propane conversion kit

BACnet gateway LON gateway

Sizing Data

	Model	Input		Output		AFUE	Thermal Efficiency	Comb. Efficiency	Gas Conn. Size	Water Conn. Size	Shipp Weid	
_		BTU/h	kW	BTU/h	kW		%	%	inches	inches	Lbs	kg
[BNTH150	150,000	44.0	138,000	40.4	95.0	N/A	N/A	½ NPT	1 NPT	228	104
[BNTH 210	210,000	61.5	194,000	61.5	95.0	N/A	N/A	½ NPT	1 NPT	270	123
[BNTH 285	285,000	83.5	264,000	77.4	95.0	N/A	N/A	¾ NPT	1¼ NPT	299	136

NOTES:

For other boiler ratings:

Boiler Horsepower: HP = Output

33,475

Radiation Surface: EDR sq. ft. = Output

150

Clearances

Appliance		Suggested Service Access Clearance						
Surface	inches	cm						
Left Side	12	31						
Right Side	12	31						
Top (for flue)	48	122						
Back	12	31						
Closet, Front	1	2.5						
Alcove, Front	24	61						
Vent	Per Vent Ma	nufacturer						
0 45 11 004 5								

Certified by CSA for zero clearance to combustible materials on all sides.

Electrical Data

Sizes		Boiler		Pump Connections Ratings			
	Volts	Phase	Amps	(System Pump and DHW Pump Connections)			
No Pump	120	Single	2*	115V – Maximum 1HP or 7.4A max			
With Pump	120	Single	Less than 6*	115V – Maximum 1HP or 7.4A max			

^{*} Minimum 15A circuit required

Vent System

	Intake (Air)	Exhaust (Vent)	Maximum	Allowable	
Size	Pipe	Pipe	Equivalen	t Length*	
150	3"	3"	100 ft	30 m	
210	3"	3"	100 ft	30 m	
285	3"	3"	20 ft	6.1 m	
200	4"	4"	100 ft	30 m	

Installations in the U.S. require exhaust vent pipe that is a combination of PVC & CPVC complying with ANSI/ASTM D1785 F441, polypropylene pipe that complies with ULC S636, or stainless steel complying with UL1738. Installations in Canada require exhaust vent pipe that is certified to ULC S636.

Intake (air) pipe may be ABS, PVC, CPVC or galvanized material.

Installer must comply fully with manufacturer's installation instructions, including use of minimum exhaust length CPVC, to maintain ANSI Z21.13 safety certification.

Closet and alcove installations do not allow the use of PVC under any circumstances


- * To calculate max equivalent length, measure the linear feet of the pipe, and add 5 feet (1.5m) for each elbow used.
- ** Allowed only if the vent pipe is no more than 20 equivalent feet longer than the air pipe.

Water Flow Requirements

					Tem	perature R	ise in °F				
		20	°F	25°F		30	°F	35	°F	40°F	
		Flow	H/L	Flow	H/L	Flow	H/L	Flow	H/L	Flow	H/L
	ize	gpm	feet	gpm	feet	gpm	feet	gpm	feet	gpm	feet
15	50	14	29	11	19	10	14	8	11	7	9
21	10	20	24	16	17	13	12	11	9	10	7
28	35	27	26	22	18	18	14	15	11	13	8

Temperature Rise in °C

	11°C		14°C		17	°C	19	°C	22°C	
	Flow	H/L								
Size	lpm	m								
150	54	8.7	43	5.8	36	4.1	31	3.4	27	2.1
210	76	7.3	61	5.1	51	3.5	43	2.7	37	2.4
285	102	7.8	81	5.3	68	4.3	58	3.2	51	2.4



All models are shipped with adapters for the air and vent that accept standard pipe of the proper size and type.

SI	SIZE		F			J		K		L (L	ength)	T (Total Length)	VE	NTØ
	_	in	ст	in	ст	in	ст	in	ст	in	ст	in cm	in	cm
1	50	18"	45.7	27"	69	23-1/2"	60	5-1/4"	13	20"	60	25-1/2" 65	3	7.6
199	/ 210	18"	45.7	27"	69	24-1/2"	60	5-1/4"	13	27"	68.6	32-1/2" 82.5	3	7.6
2	.85	19"	48	28-1/4"	72	12"	30.5	7-1/4"	18.4	27"	68.6	32-1/2" 82.5	4	11

Bradford White Corporation reserves the right to change specifications, components, features, or to discontinue products without notice.

